SIEMENS

Data sheet 6EP1961-3BA21



SITOP PSE202U/Redundancy M./DC24V/40A

SITOP PSE202U redundancy module input/output: 24 V DC/40 A suitable for decoupling two SITOP power supplies with maximal per 20 A output current

| | DO II | | |
|---|---|--|--|
| type of the power supply network | DC voltage | | |
| supply voltage at DC | 24 24 V | | |
| input voltage at DC | 24 28.8 V | | |
| utput | | | |
| voltage curve at output | Controlled, isolated DC voltage | | |
| output voltage at DC rated value | 24 V | | |
| formula for output voltage | Vin - approx. 0.5 V | | |
| output voltage | | | |
| at output 1 at DC rated value | 24 V | | |
| output voltage adjustable | No No | | |
| display version for normal operation | Green LED for "both Input voltages > switching threshold"; red LED: for "at least one input voltage < switching threshold" | | |
| type of signal at output | Isolated relay contact (changeover contacts, rating 8 A/240 V AC, 24 V DC): Signals OK if both input voltages > switching threshold, setting range of threshold 20 25 V | | |
| output current | | | |
| • rated value | 40 A | | |
| • rated range | 40 A; max. aggregate current 40 A; +60 +70 °C: derating 3%/K | | |
| fficiency | | | |
| efficiency in percent | 96.6 % | | |
| power loss [W] | | | |
| at rated output voltage for rated value of the output current typical | 34 W | | |
| during no-load operation maximum | 1.5 W | | |
| afety | | | |
| galvanic isolation | yes, SELV acc. to EN 60950-1 (relay contact) | | |
| operating resource protection class | Class III | | |
| protection class IP | IP20 | | |
| MC | | | |
| standard | | | |
| • for emitted interference | EN 55022 Class B | | |
| • for interference immunity | EN 61000-6-2 | | |
| tandards, specifications, approvals | | | |
| certificate of suitability | | | |
| CE marking | Yes | | |
| UL approval | Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 | | |
| CSA approval | Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 | | |
| • EAC approval | Yes | | |
| • NEC Class 2 | No | | |
| type of certification | | | |

| CB-certificate | No | | |
|---|---|--|--|
| MTBF at 40 °C | 6 471 654 h | | |
| standards, specifications, approvals hazardous environments | | | |
| certificate of suitability | | | |
| • IECEx | No | | |
| • ATEX | No | | |
| ULhazloc approval | No | | |
| • cCSAus, Class 1, Division 2 | No | | |
| • FM registration | No | | |
| standards, specifications, approvals marine classification | | | |
| shipbuilding approval | Yes | | |
| Marine classification association | | | |
| American Bureau of Shipping Europe Ltd. (ABS) | Yes | | |
| French marine classification society (BV) | No | | |
| Det Norske Veritas (DNV) | Yes | | |
| Lloyds Register of Shipping (LRS) | No | | |
| ambient conditions | NO | | |
| | | | |
| ambient temperature | 25 LGO: with potural convention | | |
| during operation | -25 +60; with natural convection | | |
| during transport | -40 +85 | | |
| • during storage | -40 +85 | | |
| environmental category according to IEC 60721 | Climate class 3K3, 5 95% no condensation | | |
| connection method | | | |
| type of electrical connection | screw terminal | | |
| • at input | Input, output and ground: 1 screw terminal each for 0.33 10 mm ² single- | | |
| 6-m | core/finely stranded | | |
| for auxiliary contacts | Relay contact: 3 screw terminals for 0.5 2.5 mm² single-core/finely stranded | | |
| mechanical data | | | |
| width × height × depth of the enclosure | 70 × 125 × 120 mm | | |
| installation width × mounting height | 70 mm × 225 mm | | |
| required spacing | | | |
| • top | 50 mm | | |
| • bottom | 50 mm | | |
| • left | 0 mm | | |
| • right | 0 mm | | |
| fastening method | Snaps onto DIN rail EN 60715 35x7.5/15 | | |
| standard rail mounting | Yes | | |
| S7 rail mounting | No | | |
| • wall mounting | No | | |
| housing can be lined up | Yes | | |
| net weight | 0.5 kg | | |
| further information internet links | | | |
| internet link | | | |
| • to website: Industry Mall | https://mall.industry.siemens.com | | |
| to web page: selection aid TIA Selection Tool | https://www.siemens.com/tstcloud | | |
| to web page: power supplies | https://siemens.com/sitop | | |
| to website: CAx-Download-Manager | https://siemens.com/cax | | |
| • to website: Industry Online Support | https://support.industry.siemens.com | | |
| additional information | | | |
| other information | Specifications at rated input voltage and ambient temperature +25 °C (unless | | |
| | otherwise specified) | | |
| security information | | | |
| security information | Siemens provides products and solutions with industrial cybersecurity functions that support the secure operation of plants, systems, machines and networks. In order to protect plants, systems, machines and networks against cyber threats, it is necessary to implement – and continuously maintain – a holistic, state-of-the-art industrial cybersecurity concept. Siemens' products and solutions constitute one element of such a concept. Customers are responsible for preventing unauthorized access to their plants, systems, machines and networks. Such systems, machines and components should only be connected to an enterprise network or the internet if and to the extent such a connection is necessary and only when appropriate security measures (e.g. firewalls and/or network segmentation) are in place. For additional information on industrial cybersecurity measures that may be implemented, please visit | | |

www.siemens.com/cybersecurity-industry. Siemens' products and solutions undergo continuous development to make them more secure. Siemens strongly recommends that product updates are applied as soon as they are available and that the latest product versions are used. Use of product versions that are no longer supported, and failure to apply the latest updates may increase customer's exposure to cyber threats. To stay informed about product updates, subscribe to the Siemens Industrial Cybersecurity RSS Feed under https://www.siemens.com/cert. (V4.7)

| | | Version | Classification |
|--|----------|---------|------------------|
| | eClass | 14 | 27-04-07-01 |
| | eClass | 12 | 27-04-07-01 |
| | eClass | 9.1 | 27-04-07-01 |
| | eClass | 9 | 27-04-07-01 |
| | eClass | 8 | 27-04-90-02 |
| | eClass | 7.1 | 27-04-90-02 |
| | eClass | 6 | 27-04-90-02 |
| | ETIM | 9 | EC002540 |
| | ETIM | 8 | EC002540 |
| | ETIM | 7 | EC002540 |
| | IDEA | 4 | 4130 |
| | UNSPSC | 15 | 39-12-10-04 |
| provals Certificates | | | |
| eneral Product Approval | | | Marine / Shippin |
| anufacturer Declaration of Contion formity EG-Kee | UK CA | UL DE | ABS |
| J.Å DNV DNV | | | |
| | | | |



